




TEST REPORT C10/11 SPECIFIC TECHNICAL PRESCRIPTIONS REGARDING POWER-GENERATING PLANTS OPERATING IN PARALLEL TO THE DISTRIBUTION NETWORK	
Report Reference No.....:	230401862SHA-002
Date of issue.....:	2023-07-26
Total number of pages.....:	69 pages
Testing Laboratory:	Intertek Testing Services Shanghai.
Address.....:	Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China.
Tested by (name + signature)	Issac Chen <i>Issac Chen</i>
Approved by (name + signature)	Sleif Sui <i>Sleif Sui</i>
Applicant's name:	Afore New Energy Technology (Shanghai) Co., Ltd.
Address.....:	Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China. 201112
Test specification:	
Standard.....:	C10/11: ed.2.2, 15 Mar 2021
Test procedure.....:	Type approval for type A
Non-standard test method.....:	N/A
Test Report Form No:	C10/11_a
Test Report Form(s) Originator.....:	Intertek Guangzhou
Master TRF.....:	Dated 2019-10
This publication may be reproduced in whole or in part for non-commercial purposes as long as Intertek is acknowledged as copyright owner and source of the material. Intertek takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	

Test item description:	Grid-connected PV inverter
Trade Mark.....:	Afore
Manufacturer.....:	Same as Applicant
Model/Type reference.....:	BNT030KTL, BNT036KTL, BNT040KTL, BNT050KTL, BNT060KTL
Rating.....:	See below Specifications table

Specifications table					
Model	BNT030KTL	BNT036KTL	BNT040KTL	BNT050KTL	BNT060KTL
PV input					
P _{pv} Max(W)	45000	54000	60000	75000	90000
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	48 x 2	48 x 3	48 x 3	48 x 3	48 x 4
Number MPP trackers	2	3	3	3	4
Number input strings	2/3	2/2/2	2/2/2	2/2/3	2/2/2/2
Max. PV input current / strings (A)	38 x 2	38 x 3	38 x 3	40 x 3	38 x 4
MPPT voltage range (Vdc)	200-1000	200-1000	200-1000	200-1000	200-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850	500-850
AC Grid (output)					
Normal AC Voltage (V _{AC})	3P+N+PE/3P+PE 230/400				
Frequency (Hz)	50				
Normal AC Current (A)	43.5	52.2	58	72.5	87
Max. cont. output current (A)	48	60	65	80	96
Normal Power (W)	30000	36000	40000	50000	60000
Rated Apparent Power (VA)	30000	36000	40000	50000	60000
Max. cont. Power (W)	30000	36000	40000	50000	60000
Max. cont. Apparent Power (VA)	30000	36000	40000	50000	60000
Power factor(adjustable)	1.0(-0.8~ +0.8)				
Others					
Protective class	Class I				
Ingress protection (IP)	IP65				
Temperature (°C)	-25°C to +60°C				
Inverter Isolation	Non-isolated				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Software version	DSP:V06 CPLD:V06 HMI:V06				

Summary of testing:	
Tests performed (name of test and test clause): All applicable tests Remark: Other than special notice, for all clauses, the model BNT060KTL is type tested and valid for other models.	Testing location: Intertek Testing Services Shanghai. Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China.

Copy of marking plate



Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation
3. The model name: BNTxxxKTL, xxx means 030, 036, 040, 050, 060.
4. The information covered by on marking plate was irrelevant to this report.

Test item particulars:	
Temperature range	-25°C ~ 60°C
AC Overvoltage category.....:	<input type="checkbox"/> OVC I <input type="checkbox"/> OVC II <input checked="" type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
DC Overvoltage category	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
IP protection class	IP65
Possible test case verdicts:	
- test case does not apply to the test object.....:	N/A (Not applicable)
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement	F (Fail)
Testing:	
Date of receipt of test item.....:	2023-04-27
Date (s) of performance of tests.....:	2023-04-27 to 2023-07-26
General remarks:	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.</p> <p>When determining for test conclusion, measurement uncertainty of tests has been considered. This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. The test report only allows to be revised only within the report defined retention period unless standard or regulation was withdrawn or invalid.</p> <p>Throughout this report a point is used as the decimal separator.</p>	

General product information:


The testing item is a grid-connected type inverter for indoor or outdoor installation.

The Inverter is three-phase type and no isolation between PV input and AC output.

The relays are designed to redundant structure that controlled by separately.

The master controller and slave controller are used together to control relay open or close, if the single fault on one controller, the other controller can be capable to open the relay, so that still providing safety means.

The topology diagram as following:



Model differences:

All models are identical with hardware version and software version, the output power is derating by software.

Model BNT030KTL has 2 MPPT tracker with 5 input strings,

Model BNT036KTL and BNT040KTL has 3 MPPT trackers with 6 input strings,

Model BNT050KTL has 3 MPPT trackers with 7 input strings,

Model BNT060KTL has 4 MPPT trackers with 8 input strings,

Except as noted, the model BNT060KTL is as the representative test model in this report.

Factory information: Afore New Energy Technology (Shanghai) Co., Ltd.

Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China. 201112

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
ANNEXE D	Technical basic requirements regarding the power-generating units		P
D.1	General	This report is only evaluated and tested for generating unit; The generating plant incorporated with the generating unit shall further consider this clause and sub-clause.	P
	In line with the scope of these technical specifications as well as the CENELEC standards EN 50549-1 and EN 50549-2, these requirements are applicable to all kinds of generation of electrical energy, including energy storage systems.	In line with the scope of EN 50549-1	P
D.2	Order of priorities		P
	If different requirements on the power-generating unit interfere with each other, the hierarchy listed in EN 50549-1 or EN 50549-2 shall be respected		P
	In brief, the standard specifies following hierarchy: 1. Generating unit protection, including regarding the prime mover. 2. Interface protection and protection against fault within the power-generating plant; 3. Voltage support during faults and voltage steps; 4. The lower value of: remote control command on active power limitation setpoint from the DSO and local response to overfrequency; 5. Local response to underfrequency if applicable; 6. Reactive power and active power (P(U)) controls; 7. Other control commands on active power set point for e.g. market, economic reasons, self-consumption optimization.		P
D.3	Integrated automatic separation system		P
	This clause is applicable to power-generating units with a maximum power ≤ 30 kVA.		P
	An integrated automatic separation system is strongly recommended in order to facilitate the installation procedure. Indeed, if the power-generating unit is not equipped with such an integrated system, an external device must be used	Incorporating integrated automatic separation system	P
	For the integrated automatic separation system, the requirements of this clause apply.		P
	Following protection functions are required: • Overvoltage 10 min mean • Overvoltage • Undervoltage • Overfrequency • Underfrequency • A means to detect island situation (LoM) according to EN 62116.	(See appended table D.3)	P

C10/11: ed.2.2, 15 Mar 2021											
Clause	Requirement - Test	Result - Remark	Verdict								
	All of these protection functions must comply with the relevant requirements in EN 50549-1 (in edition 2019, section 4.9.3		P								
	The integrated automatic separation system must have single fault tolerance according to EN 50549-1.	Two series relays in each line and may independent operation for each relay.	P								
	The integrated automatic separation system must be set in accordance with the settings as specified in ANNEXE C		P								
D.4	Operating ranges		P								
	Generating plants shall have the capability to operate in the operating ranges specified below regard-less of the topology and the settings of the interface protection.		P								
D.4.1	Operating frequency range		P								
	This clause is not applicable to backup power systems as specified in § 2.2.1.	Not backup power system	N/A								
	The power-generating unit must comply with the minimum requirements of the applicable standard EN 50549 or EN 5055-2 on the operating frequency range (edition 2019, see clause 4.4.2 « Operating frequency range »)	Comply with EN 50549-1	P								
	In brief, the requirements in the standard are as follows:	(See appended table D.4.1)	P								
	<table border="1"> <thead> <tr> <th>Frequency domain</th> <th>Duration</th> </tr> </thead> <tbody> <tr> <td>47,5 Hz – 49,0 Hz</td> <td>30 minutes</td> </tr> <tr> <td>49,0 Hz – 51,0 Hz</td> <td>Permanent</td> </tr> <tr> <td>51,0 Hz – 51,5 Hz</td> <td>30 minutes</td> </tr> </tbody> </table>	Frequency domain	Duration	47,5 Hz – 49,0 Hz	30 minutes	49,0 Hz – 51,0 Hz	Permanent	51,0 Hz – 51,5 Hz	30 minutes		
Frequency domain	Duration										
47,5 Hz – 49,0 Hz	30 minutes										
49,0 Hz – 51,0 Hz	Permanent										
51,0 Hz – 51,5 Hz	30 minutes										
	Additionally, the DSO shall be informed about the capability of the power-generating unit to operate in the frequency range from 51,5 Hz and 52,5 Hz and, where appropriate, the maximum duration of operation in this frequency range.		P								
	The URD cannot without good reason refuse to apply wider frequency ranges or longer minimum operating periods than those specified above, provided that the technical and economic impact is limited.	Comply with above requirements	P								
D.4.2	Maximum admissible power reduction in case of underfrequency		P								
	This clause is not applicable to backup power systems as specified in § 2.2.1.	Not backup power system	N/A								
	In general, a power-generating unit must continue to operate in case of a reduction of the frequency at the point of connection. This means that, in underfrequency, the power-generating unit should reduce the output power as little as possible and at least being capable of staying above the limit specified hereafter.		P								

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	Where the technical capabilities of the power-generating unit are influenced by ambient conditions, these technical capabilities may be demonstrated using the following reference conditions: <ul style="list-style-type: none"> • Temperature: 0 °C • Altitude: between 400 and 500 m • Humidity: between 15 and 20 g H₂O/kg air 		P
D.4.2.1	Limit for non-synchronous power-generating technology (Power Park Modules)	(See appended table D.4.2.1)	P
	The power-generating unit must comply with the most stringent requirement of EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.4.3 « Minimal requirement for active power delivery at underfrequency »).	Comply with EN 50549-1	P
D.4.2.2	Limits for synchronous power-generating technology	Not synchronous power-generating	N/A
	In steady state (from t ₂ onwards), the power-generating unit must comply with the relevant default requirement of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see section 4.4.3 « Minimal requirement for active power delivery at underfrequency »).		N/A
	Additionally, in the transient time (between t ₁ and t ₂), the power-generating unit must comply with the relevant most stringent requirement of EN 50549-1 or EN 50549-2. (In edition 2019 of the standard, the relevant requirements can be found in clause 4.4.3 « Minimal requirement for active power delivery at underfrequency »).		N/A
D.4.3	Continuous operating voltage range		P
	The power-generating unit must comply with the relevant requirement of EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.4.4 « Continuous operating voltage range »).	Comply with EN 50549-1	P
	In brief, the requirement in the standard specifies the power-generating plant should be capable to operate continuously when the voltage at the point of connection is within the following range:	(See appended table D.4.3)	P
	• For a connection to the low voltage network: 85 % $U_n < U < 110 \% U_n$ where $U_n = 230 V$		P
	• For a connection to the high voltage network: 90 % $U_c < U < 110 \% U_c$ where U_c is the declared voltage.		N/A
	It is also allowed to reduce apparent power in case of voltage is below respectively 95 % U_n or 95 % U_c .		P
D.5	Immunity to disturbances		P
	Independent of the topology and the settings of the interface protection, a power-generating unit must have the following withstand capabilities.		P
D.5.1	Rate of change of frequency (RoCoF) immunity		P
	This clause does not apply to backup power systems as specified in § 2.2.1.	Not backup power system	N/A

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	The power-generating unit must comply with the relevant requirements of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see section 4.5.2 « Rate of change of frequency (RoCoF) immunity ») taking the additional modifications and information specified hereunder into account.	(See appended table D.5.1)	P
	The power-generating unit shall have the capability to stay connected and operate when the frequency at the point of connection changes with the frequency against time profiles as depicted in the figures hereunder. When considering a sliding measurement window of 500ms, these profiles have a maximum RoCoF of 2 Hz/s.		P
	For synchronous generating technology, this requirement is more stringent than the default value in the applicable standard EN 50549-1 or EN 50549-2 (2 Hz/s instead of 1 Hz/s) as, in contrast with the standard, no distinction is made between power-generating technologies.	Not synchronous power-generating	N/A
D.5.2	Under-voltage ride through UVRT		P
	This section is not applicable to backup power systems as specified in § 2.2.1.	Not backup power system	N/A
	For a power-generating unit that is part of a power-generating module with a power ≥ 1 MW (type B in accordance with NC RfG) this paragraph is mandatory.		N/A
	For a power-generating unit that is part of a power-generating module with a power < 1 MW, this paragraph is non-mandatory and to be considered as an orienting capability, not as a hard requirement. However, the real withstand capability to voltage dips shall be provided during the homologation process.	Considered as an orienting capability	P
	The power-generating unit must comply with the relevant requirements of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.5.3 « Under-voltage ride through (UVRT) »), with the following change: • The voltage-time profiles are to be replaced by the profiles hereunder.	(See appended table D.5.2)	P
	As a consequence, for synchronous generating technology this profile is more stringent than the default requirement in EN 50549-1 or EN 50549-2.	Not synchronous power-generating	N/A
	For some power-generating technologies, the behaviour of the power-generating unit during and after voltage dips may be impacted by the short circuit power available at the point of connection.		N/A
	For such technologies different cases can be considered:		N/A
	• Compliance with this UVRT requirement can be demonstrated considering a ratio of 10 between the available short circuit power at the connection point and the maximum power of the considered power-generating module. In this case, no further checks are needed.		N/A

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	<ul style="list-style-type: none"> If not, the manufacturer must declare the minimum short-circuit power conditions for which the UVRT-requirement can be complied with. This value shall be considered during the installation process. 		N/A
	In line with EN 50549-1 or EN 50549-2 at least 90% of the pre-fault power or 90% of the available power whichever is the smallest, shall be resumed as fast as possible, but at the latest within the following default time after the voltage returned to the continuous operating voltage range (85% $U_n < U < 110\% U_n$ for a connection to a low-voltage distribution network; 90% $U_c < U < 110\% U_c$ for a connection to a high-voltage distribution network):		P
	<ul style="list-style-type: none"> 3 seconds for a power-generating unit with synchronous generating technology 		N/A
	<ul style="list-style-type: none"> 1 second for a power-generating unit with non-synchronous generating technology 		P
	Another site specific maximum allowed time is to be agreed during the commissioning process. This decision must be taken with the DSO in coordination with the TSO.		N/A
	For a backup power system connected to the high voltage distribution network as specified in §2.2.1, the general requirement is this clause may be relaxed, replacing the voltage-time profile by the figure underneath.	Not backup power system	N/A
D.5.3	Over-voltage ride through (OVRT)		N/A
	Requirement under consideration for a future edition. No requirement in this edition.		N/A
D.6	Active response to frequency deviations		P
D.6.1	Power response to overfrequency		P
	This clause is not applicable to backup power system as specified in section §2.2.1	Not backup power system	N/A
	The power-generating unit must comply with the relevant requirements of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see 4.6.1 « Power response to overfrequency ») taking into account the additional modifications and information specified hereunder.	Comply with EN 50549-1	P
	Instead of the default maximum step response time of 30s specified in the standards EN 50549-1 and EN 50549-2, the following dynamic step response characteristics are required:		P
	<ul style="list-style-type: none"> For synchronous power-generating technologies For power-generating units base on a gas turbine or an internal combustion engine with technical specificities not allowing compliance with the prescriptions applied by default as de-scribed above, the following alternative prescription, relating to a minimum power gradient in increasing or decreasing frequency, is applicable:		N/A
	- If $P_{max} \leq 2$ MW at minimum 1,11 % P_{max} per second		N/A

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	- If Pmax >2 MW at minimum 0,33 % Pmax per second		N/A
	• For non-synchronous power-generating technology	(See appended table D.6.1)	P
	The figure hereunder clarifies the terms « Step response time» and « Settling time». In this clause, the 'Value' is the active power and the tolerance is 10%.		P
	In line with the default requirement of the applicable standard EN 50549-1 :2019 or EN 50549-2: 2019, power-generating units reaching their minimum regulating level shall, in the event of further frequency increase, maintain this power level until a frequency decrease results in a power setpoint which is again above this level.	Comply with EN 50549-1	P
	The optional deactivation threshold f_{stop} is not required. In case f_{stop} is implemented, it shall be deactivated.		P
	At the time of deactivation of the active power frequency response (= frequency goes down below the threshold frequency f_1), the active power can be increased to up to the level of the available power. Nevertheless this shall be done respecting a power limit with a gradient of 10% Pmax/min.		P
	For energy storage systems with a connection to the high-voltage distribution network, the DSU might, for justified technical or security reasons, agree with the DSO on applicable minimum state of charge limits in his connection agreement.		N/A
	The settings must be protected from unpermitted interference (e.g. by a password or seal).		P
	Automatic disconnection and reconnection as alternative for the droop function are not permitted by default as per the TSO provisions.		P
D.6.2	Power response to underfrequency	Not an energy store system	N/A
	The power-generating unit must comply with the relevant requirements of the applicable EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.6.2 « Power response to underfrequency ») taking additional modifications and information as specified hereunder into account.		N/A
	This clause is applicable to energy storage systems. For justified technical or security reasons, the DSU might agree with the DSO (in his connection agreement is the power-generating plant is connected to the high-voltage distribution network) on applicable maximum state of charge limits in his connection agreement.		N/A
	This clause is optional for all other power-generating units. When, in such units, the capability of activating active power response to underfrequency is activated, the power-generating units must comply with the requirements of this clause.		N/A

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	Instead of the default maximum step response time of 30s in EN 50549-1 and EN 50549-2, the re-quired dynamic step response characteristics (step response time and settling time) are identical to those stipulated above regarding the power response to overfrequency, including the alternative approach for power-generating units based on a gas turbine or an internal combustion engine (see D.6.1).		N/A
	The settings must be protected from unpermitted interference (e.g. by a password or seal).		P
D.7	Power response to voltage changes		P
D.7.1	Voltage support by reactive power		P
	A backup power system as referred to in section §2.2.1, must not comply with the requirements of this clause. Instead, for such a system, the power factor must be as close to 1 as possible and may definitely not fall below the limit of 0.85 during in-parallel operation. No control mode at all for the reactive power is imposed by the DSO.	Not backup power system	N/A
	The power-generating plant must at least comply with the corresponding requirements of the applicable standard EN 50549-1 or EN 50549-233 (edition 2019, see clause 4.7.2 « Voltage support by reactive power ») taking the modifications and additional information specified hereunder into account. It is usually the power-generating unit itself that meets this requirement, which is assessed at the time of the homologation. In the other cases, if for example additional equipment such as a capacitor bank is necessary in combination with the power-generating unit, this will be evaluated by the DSO during the procedure for commissioning.	Comply with EN 50549-1	P
	For a power-generating plant with a maximum power \leq 250 kVA connected to the high-voltage distribution network, the DSU may decide to comply to the equivalent requirements of EN 50549-1 rather than those of EN 50549-2.		N/A
	The reactive power capability shall be evaluated at the terminals of the power-generating unit (including, when applicable, the step-up transformer specific to the power-generating unit).	(See appended table D.7.1)	P
	The real reactive power capabilities of the power-generating unit at the terminals should be communicated to the DSO. This can be done during the process of homologation.		P
	If the capabilities exceed the minimum requirement, and as far as this has only limited technical and economic impact, the DSU is not allowed to refuse without justification the DSO to make use of the reactive power capability (this is not applicable to a small power-generating plant (as defined in chapter 4)).		P
	The settings of the control mode must be protected from unpermitted interference (e.g. by a password or seal).		P

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
D.7.1.1	Specific for a small power-generating plant		P
	By default, the power generation unit must operate according to the following rules:		P
	• When the voltage $\leq 105\% U_n$: $\cos \phi = 1$ ($Q=0$)		P
	• When the voltage $> 105\% U_n$: free operation with $1 \geq \cos \phi > 0,9$ under-excited. (no over-excited operation allowed)		P
D.7.1.2	Specific for another (not small) power-generating plant		P
	If applicable, the details of the reactive power control mode to be activated in the power-generating unit shall be provided by the DSO during the installation procedure. This setting might be reviewed by the DSO during the lifetime of the power-generating module.		P
	If the power-generating plant is connected to the high voltage distribution network, it may be necessary to use additional resources such as, for example, a capacitor bank to meet the previous requirements related to the supply of reactive power. If the power-generating unit is disconnected, they must be disconnected as well.	Not connected to the high voltage distribution network	N/A
	For a synchronous power-generating unit that is part of a power-generating module with a maximum power of ≥ 1 MW (type B according to NC RfG), the following specific requirement is also applicable:	Not synchronous power-generating unit	N/A
	Alternatively to the Q(U) control mode specified above, a synchronous power-generating unit of type B (power ≥ 1 MW) shall be equipped with a permanent automatic excitation control system that can provide constant alternator terminal voltage at a selectable setpoint without instability over the entire operating range of the synchronous power-generating module. When the setpoint gives rise to a re-active power exchange beyond the capability requirements above, the reactive power exchange may be kept at the limits of the required capability.		N/A
	The setpoint must be selectable in the continuous operating voltage range (see section D.4.3) and is given by the DSO.		P
	The DSO can give the required instructions to make the selection of the setpoint possible remotely by the DSO's control center (see § 7.13), respecting the applicable regional legal framework.		P
D.7.2	Voltage related active power reduction P(U)	(See appended table D.7.2)	P

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	Voltage relating active power reduction is allowed and even recommended in order to avoid disconnection due to the operation of the overvoltage protection. When implemented, the power-generating unit must comply with the relevant requirements of the applicable standard EN 50549-1 or EN50549-2 (edition 2019, see clause 4.7.3 « Voltage related active power reduction »).	Comply with EN 50549-1	P
D.7.3	Provision of additional fast reactive current during faults and voltage steps		P
	This Section is only applicable to non-synchronous power-generating units connected to a high volt-age distribution network and are not part of a small power-generating plant.		P
	For power-generating units that are part of a power-generating module with a maximum power <1 MW, there is no capability requirement. However, if such a generating module has the capability to provide additional fast reactive current during faults and voltage steps, this function must be deactivated by default.		P
	Power-generating units that are part of a power-generating module with a maximum power ≥ 1 MW must comply with the relevant requirements of the standard EN 50549-2 (edition 2019, see clause 4.7.4.2.1 « Voltage support during faults and voltage steps »), taking the additional information specified in this Section into account. By default, this function must be deactivated.		P
	A directly connected asynchronous machine cannot provide voltage support in a controlled manner with regard to short circuit currents as a consequence of faults or when there are sudden voltage variations. The DSO will include these elements in its assessment of the demand for connection.		N/A
D.8	Connection and reconnection		P
	The power-generating unit must comply with the relevant requirements of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.10 « Connection and starting to generate electrical power ») taking the additional information specified hereunder into account.	Comply with EN 50549-1	P
	Connection and reconnection after tripping of the interface protection relay is subject to the conditions listed in the table hereunder. These settings are different than the default settings of EN 50549-1 and EN 50549-2.	(See appended table D.8)	P
	The automatic connection and reconnection is allowed if the abovementioned conditions are met.		P

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	If, at the power-generating unit connected to the HV distribution network, no distinct sets of conditions can be applied, it is not possible to make a distinction between the two connection modes, the conditions must be chosen such as they meet both sets of conditions.	Not connected to the HV distribution network	N/A
D.9	Ceasing and reduction of active power on set point		P
	This clause is not applicable to the backup power systems specified in §2.2.1.	Not backup power system	N/A
D.9.1	Ceasing active power	(See appended table D.9)	P
	The power-generating unit must comply with the relevant requirements of the applicable standard EN 5054-1 or EN 50549-2 (edition 2019, see clause 4.11.1 « Ceasing active power ») taking into account the additional information specified hereunder.	Comply with EN 50549-1	P
	In brief, the requirements in the standards are the following:		P
	For modules with a power > 800 W, a logic interface to cease the production of active power within 5 seconds after receiving the instruction is required.		P
	Remote operation is optional		P
	Respecting the regional regulatory provisions, the DSO can request additional equipment for a remote operation of this logic interface.		P
	Unless defined otherwise by the DSO, this logic interface is based on a contact rather than using a communicated protocol.		P
D.9.2	Reduction of active power on set point	(See appended table D.9)	P
	The requirement of this Section is applicable only to the power-generating units that are part of:		P
	• a power-generating module with a maximum power of ≥ 1 MW		N/A
	• a power-generating plant with a maximum power of > 250 kVA, if the DSO so requires, in accordance with the regional regulations.		P
	The power-generating module must comply with the relevant requirements of the applicable standard EN 50549-1 or EN 50549-2 (edition 2019, see clause 4.11.2 « Reduction of active power on set point ») taking into account the additional information specified hereunder. Generally, the power-generating unit complies with this requirement, which is assessed when homologated. Otherwise, if, for example, additional equipment such as a capacitor bank is required in combination with the power-generating unit, this will be evaluated by the DSO during the commissioning procedure.	Comply with EN 50549-1	P

C10/11: ed.2.2, 15 Mar 2021			
Clause	Requirement - Test	Result - Remark	Verdict
	<p>In brief, the requirements in the standard are the following: For type B modules: The settings of the limit must be possible with a maximum increment of 10%. Reduction of the power generation to the respective limit in a range of maximum 0,66 % Pn/ s and of minimum 0,33 % Pn/ s Disconnection of the network is allowed when below minimum regulating level Remote operation is optional</p>		P
	<p>Depending of the modalities specified in section D.10 hereafter, the DSO can request additional equipment for a remote operation of this reduction.</p>		N/A
D.10	Communication – Remote monitoring and control		N/A

Appended Table - Testing Result

8.2.3		TABLE: Flicker				P		
Flicker measurement								
According to EN 61000-3-3/EN 61000-3-11								
Model: BNT060KTL								
Value		D _c (%)	D _{max} (%)	d(t) – 500ms	P _{st}	P _{lt}		
Limit		3.30	4.00	3.30%	1.00	0.65		
Test value	L1	0.030	0.365	0.0	0.119	0.116		
	L2	0.042	0.290	0.0	0.128	0.123		
	L3	0.758	1.296	0.0	0.179	0.151		
Limit		dc[%]	dmax[%]	d(t)[ms]	Pst	Plt		
Limit		3.30	4.00	500 3.30%	1.00	0.65 N:12		
No.								
1	0.026	Pass	0.258	Pass	0.0	Pass	0.117	Pass
2	0.030	Pass	0.287	Pass	0.0	Pass	0.114	Pass
3	0.027	Pass	0.252	Pass	0.0	Pass	0.116	Pass
4	0.011	Pass	0.214	Pass	0.0	Pass	0.115	Pass
5	0.028	Pass	0.221	Pass	0.0	Pass	0.114	Pass
6	0.024	Pass	0.365	Pass	0.0	Pass	0.116	Pass
7	0.023	Pass	0.246	Pass	0.0	Pass	0.115	Pass
8	0.025	Pass	0.266	Pass	0.0	Pass	0.116	Pass
9	0.027	Pass	0.244	Pass	0.0	Pass	0.119	Pass
10	0.026	Pass	0.224	Pass	0.0	Pass	0.117	Pass
11	0.014	Pass	0.250	Pass	0.0	Pass	0.116	Pass
12	0.029	Pass	0.256	Pass	0.0	Pass	0.116	Pass
Result		Pass	Pass	Pass		Pass	0.116	Pass
L1 phase								
Limit		dc[%]	dmax[%]	d(t)[ms]	Pst	Plt		
Limit		3.30	4.00	500 3.30%	1.00	0.65 N:12		
No.								
1	0.023	Pass	0.290	Pass	0.0	Pass	0.126	Pass
2	0.020	Pass	0.269	Pass	0.0	Pass	0.123	Pass
3	0.017	Pass	0.240	Pass	0.0	Pass	0.128	Pass
4	0.015	Pass	0.234	Pass	0.0	Pass	0.122	Pass
5	0.024	Pass	0.153	Pass	0.0	Pass	0.123	Pass
6	0.012	Pass	0.181	Pass	0.0	Pass	0.123	Pass
7	0.031	Pass	0.164	Pass	0.0	Pass	0.123	Pass
8	0.042	Pass	0.190	Pass	0.0	Pass	0.124	Pass
9	0.034	Pass	0.172	Pass	0.0	Pass	0.123	Pass
10	0.033	Pass	0.187	Pass	0.0	Pass	0.121	Pass
11	0.021	Pass	0.217	Pass	0.0	Pass	0.118	Pass
12	0.031	Pass	0.204	Pass	0.0	Pass	0.122	Pass
Result		Pass	Pass	Pass		Pass	0.123	Pass
L2 phase								

	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.118 Pass	0.257 Pass	0.0 Pass	0.117 Pass	
2	0.156 Pass	0.209 Pass	0.0 Pass	0.163 Pass	
3	0.078 Pass	0.165 Pass	0.0 Pass	0.179 Pass	
4	0.580 Pass	1.168 Pass	0.0 Pass	0.142 Pass	
5	0.153 Pass	1.191 Pass	0.0 Pass	0.157 Pass	
6	0.106 Pass	0.303 Pass	0.0 Pass	0.118 Pass	
7	0.224 Pass	0.437 Pass	0.0 Pass	0.156 Pass	
8	0.115 Pass	0.219 Pass	0.0 Pass	0.146 Pass	
9	0.758 Pass	1.296 Pass	0.0 Pass	0.162 Pass	
10	0.693 Pass	1.189 Pass	0.0 Pass	0.153 Pass	
11	0.211 Pass	0.539 Pass	0.0 Pass	0.154 Pass	
12	0.071 Pass	0.275 Pass	0.0 Pass	0.148 Pass	
Result	Pass	Pass	Pass	Pass	0.151 Pass

L3 phase

8.2.3		TABLE: Flicker				P					
Flicker measurement											
According to EN 61000-3-3/EN 61000-3-11											
Model: BNT030KTL											
Value		D _c (%)		D _{max} (%)		d(t) – 500ms		P _{st}		P _{lt}	
Limit		3.30		4.00		3.30%		1.00		0.65	
Test value	L1	0.031		0.337		0.0		0.118		0.113	
	L2	0.044		0.333		0.0		0.127		0.120	
	L3	0.258		0.525		0.0		0.298		0.155	
Limit		dc[%]		dmax[%]		d(t)[ms]		Pst		Plt	
Limit		3.30		4.00		500 3.30%		1.00		0.65 N:12	
No.											
1	0.023	Pass	0.305	Pass	0.0	Pass	0.118	Pass			
2	0.027	Pass	0.264	Pass	0.0	Pass	0.116	Pass			
3	0.029	Pass	0.291	Pass	0.0	Pass	0.115	Pass			
4	0.028	Pass	0.299	Pass	0.0	Pass	0.113	Pass			
5	0.028	Pass	0.230	Pass	0.0	Pass	0.112	Pass			
6	0.019	Pass	0.243	Pass	0.0	Pass	0.112	Pass			
7	0.028	Pass	0.337	Pass	0.0	Pass	0.111	Pass			
8	0.025	Pass	0.260	Pass	0.0	Pass	0.110	Pass			
9	0.023	Pass	0.238	Pass	0.0	Pass	0.112	Pass			
10	0.031	Pass	0.221	Pass	0.0	Pass	0.112	Pass			
11	0.022	Pass	0.289	Pass	0.0	Pass	0.113	Pass			
12	0.028	Pass	0.302	Pass	0.0	Pass	0.110	Pass			
Result		Pass		Pass		Pass		Pass	0.113	Pass	
L1 phase											
Limit		dc[%]		dmax[%]		d(t)[ms]		Pst		Plt	
Limit		3.30		4.00		500 3.30%		1.00		0.65 N:12	
No.											
1	0.007	Pass	0.222	Pass	0.0	Pass	0.107	Pass			
2	0.019	Pass	0.249	Pass	0.0	Pass	0.110	Pass			
3	0.017	Pass	0.307	Pass	0.0	Pass	0.119	Pass			
4	0.025	Pass	0.299	Pass	0.0	Pass	0.116	Pass			
5	0.033	Pass	0.274	Pass	0.0	Pass	0.119	Pass			
6	0.021	Pass	0.333	Pass	0.0	Pass	0.122	Pass			
7	0.044	Pass	0.243	Pass	0.0	Pass	0.120	Pass			
8	0.026	Pass	0.321	Pass	0.0	Pass	0.127	Pass			
9	0.024	Pass	0.277	Pass	0.0	Pass	0.123	Pass			
10	0.030	Pass	0.263	Pass	0.0	Pass	0.123	Pass			
11	0.028	Pass	0.295	Pass	0.0	Pass	0.125	Pass			
12	0.036	Pass	0.285	Pass	0.0	Pass	0.122	Pass			
Result		Pass		Pass		Pass		Pass	0.120	Pass	
L2 phase											


	dc[%]	dmax[%]	d(t)[ms]	Pst	Plt
Limit	3.30	4.00	500 3.30%	1.00	0.65 N:12
No. 1	0.258 Pass	0.334 Pass	0.0 Pass	0.159 Pass	
2	0.140 Pass	0.312 Pass	0.0 Pass	0.127 Pass	
3	0.027 Pass	0.525 Pass	0.0 Pass	0.130 Pass	
4	0.090 Pass	0.376 Pass	0.0 Pass	0.298 Pass	
5	0.058 Pass	0.324 Pass	0.0 Pass	0.119 Pass	
6	0.026 Pass	0.197 Pass	0.0 Pass	0.109 Pass	
7	0.035 Pass	0.217 Pass	0.0 Pass	0.111 Pass	
8	0.016 Pass	0.214 Pass	0.0 Pass	0.107 Pass	
9	0.016 Pass	0.211 Pass	0.0 Pass	0.103 Pass	
10	0.011 Pass	0.201 Pass	0.0 Pass	0.102 Pass	
11	0.024 Pass	0.244 Pass	0.0 Pass	0.103 Pass	
12	0.069 Pass	0.222 Pass	0.0 Pass	0.103 Pass	
Result	Pass	Pass	Pass	Pass	0.155 Pass

L3 phase


8.2.4	TABLE: Current harmonics emission test(EN 61000-3-12)						
Model	BNT060KTL						
Harmonic	L1		L2		L3		Limits (%)
	Magnitude (A)	% of Fundamental	Magnitude (A)	% of Fundamental	Magnitude (A)	% of Fundamental	
1	86.939	99.980	86.939	99.983	86.939	99.979	--
2	0.637	0.733	0.805	0.926	0.867	0.997	8
3	0.679	0.781	0.541	0.622	0.594	0.683	21.6%
4	0.228	0.262	0.150	0.173	0.281	0.323	4
5	0.893	1.027	1.012	1.164	0.945	1.087	10.7
6	0.109	0.125	0.084	0.097	0.108	0.124	2.7
7	0.936	1.077	0.398	0.458	0.803	0.924	7.2
8	0.161	0.185	0.169	0.194	0.170	0.196	2
9	0.118	0.136	0.123	0.142	0.093	0.107	N/A
10	0.072	0.083	0.097	0.111	0.087	0.100	1.6
11	0.301	0.346	0.416	0.478	0.402	0.462	3.1
12	0.091	0.105	0.104	0.120	0.083	0.096	1.3
13	0.297	0.342	0.146	0.168	0.203	0.234	2
14	0.075	0.086	0.088	0.101	0.095	0.109	N/A
15	0.062	0.071	0.127	0.146	0.150	0.172	N/A
16	0.063	0.072	0.090	0.104	0.095	0.109	N/A
17	0.137	0.158	0.144	0.166	0.075	0.086	N/A
18	0.058	0.067	0.060	0.069	0.073	0.084	N/A
19	0.077	0.089	0.063	0.072	0.077	0.089	N/A
20	0.030	0.035	0.049	0.056	0.051	0.059	N/A
21	0.043	0.050	0.040	0.046	0.044	0.051	N/A
22	0.028	0.032	0.044	0.051	0.050	0.057	N/A
23	0.060	0.069	0.053	0.061	0.070	0.081	N/A
24	0.026	0.030	0.034	0.039	0.042	0.048	N/A
25	0.041	0.047	0.050	0.058	0.030	0.035	N/A
26	0.019	0.022	0.030	0.034	0.032	0.037	N/A
27	0.022	0.025	0.029	0.033	0.036	0.041	N/A
28	0.016	0.018	0.028	0.032	0.030	0.035	N/A
29	0.023	0.026	0.031	0.036	0.030	0.034	N/A
30	0.012	0.014	0.019	0.022	0.025	0.029	N/A
31	0.023	0.026	0.030	0.034	0.030	0.035	N/A
32	0.012	0.014	0.020	0.023	0.025	0.029	N/A
33	0.017	0.019	0.018	0.021	0.028	0.032	N/A
34	0.010	0.012	0.017	0.020	0.026	0.030	N/A
35	0.017	0.019	0.011	0.013	0.023	0.026	N/A
36	0.010	0.011	0.016	0.018	0.024	0.028	N/A
37	0.016	0.018	0.012	0.014	0.020	0.023	N/A
38	0.009	0.010	0.013	0.015	0.022	0.025	N/A
39	0.014	0.016	0.016	0.018	0.021	0.024	N/A
40	0.010	0.012	0.012	0.014	0.020	0.023	N/A
THD	-	1.977	-	1.843	-	2.039	13
PWHD	-	1.166	-	1.390	-	1.442	22

8.2.4	TABLE: Current harmonics emission test(EN 61000-3-2)						
Model	BNT030KTL						
Harmonic	L1		L2		L3		Limits (%)
	Magnitude (A)	% of Fundamental	Magnitude (A)	% of Fundamental	Magnitude (A)	% of Fundamental	
1	43.478	100.000	43.478	100.000	43.478	100.000	--
2	0.009	0.021	0.009	0.021	0.018	0.041	8
3	0.036	0.082	0.039	0.090	0.037	0.086	21.6%
4	0.013	0.029	0.007	0.017	0.016	0.037	4
5	0.036	0.083	0.035	0.080	0.029	0.067	10.7
6	0.013	0.029	0.006	0.014	0.007	0.015	2.7
7	0.007	0.016	0.010	0.022	0.010	0.023	7.2
8	0.003	0.006	0.003	0.006	0.004	0.009	2
9	0.010	0.024	0.002	0.004	0.011	0.025	N/A
10	0.002	0.004	0.005	0.012	0.005	0.012	1.6
11	0.032	0.073	0.030	0.069	0.033	0.075	3.1
12	0.010	0.024	0.007	0.015	0.008	0.019	1.3
13	0.018	0.042	0.018	0.041	0.017	0.038	2
14	0.004	0.010	0.005	0.012	0.007	0.016	N/A
15	0.006	0.014	0.003	0.008	0.004	0.009	N/A
16	0.006	0.014	0.007	0.017	0.008	0.019	N/A
17	0.008	0.018	0.007	0.016	0.011	0.026	N/A
18	0.007	0.017	0.007	0.015	0.011	0.026	N/A
19	0.026	0.060	0.023	0.052	0.022	0.051	N/A
20	0.007	0.017	0.006	0.013	0.007	0.016	N/A
21	0.007	0.016	0.006	0.013	0.007	0.017	N/A
22	0.008	0.019	0.004	0.010	0.005	0.011	N/A
23	0.013	0.031	0.014	0.032	0.015	0.034	N/A
24	0.008	0.019	0.009	0.020	0.010	0.023	N/A
25	0.020	0.046	0.019	0.043	0.017	0.039	N/A
26	0.005	0.012	0.005	0.012	0.007	0.015	N/A
27	0.004	0.009	0.004	0.010	0.005	0.012	N/A
28	0.005	0.011	0.007	0.015	0.005	0.011	N/A
29	0.012	0.028	0.012	0.028	0.012	0.027	N/A
30	0.007	0.015	0.005	0.012	0.007	0.015	N/A
31	0.019	0.044	0.020	0.046	0.018	0.041	N/A
32	0.005	0.012	0.004	0.009	0.005	0.011	N/A
33	0.004	0.009	0.003	0.006	0.004	0.010	N/A
34	0.007	0.015	0.008	0.018	0.007	0.017	N/A
35	0.010	0.022	0.011	0.025	0.015	0.035	N/A
36	0.007	0.015	0.006	0.014	0.007	0.016	N/A
37	0.014	0.033	0.016	0.037	0.017	0.038	N/A
38	0.003	0.008	0.004	0.009	0.003	0.008	N/A
39	0.002	0.005	0.002	0.005	0.002	0.005	N/A
40	0.006	0.013	0.006	0.014	0.007	0.015	N/A
THD	-	0.849	-	0.842	-	0.853	13
PWHD	-	0.613	-	0.610	-	0.638	22


D.3	Table: Undervoltage threshold stage				P
Parameter	Settings	Test 1	Test 2	Test 3	Limits
Trip value L1[V]	184	183.8	183.4	183.7	184±2.3
Trip time [ms]	150	98.8	82.4	96.6	<200
L2[V]	184	183.1	183.7	183.3	184±2.3
Trip time [ms]	150	114.4	119.6	122.4	<200
L3[V]	184	183.8	183.5	183.4	184±2.3
Trip time [ms]	150	96.4	115.2	121.6	<200
L1L2L3[V]	184	183.0	183.2	183.6	184±2.3
Trip time [ms]	150	113.2	112.0	112.7	<200




D.3	Table: Overvoltage threshold stage				P
Parameter	Settings	Test 1	Test 2	Test 3	Limits
Trip value L1 [V]	264.5	265.9	265.8	265.7	264.5±2.3
Trip time [ms]	100	114.4	104.0	111.6	<200
L2 [V]	264.5	265.0	265.8	265.3	264.5±2.3
Trip time [ms]	100	118.0	126.4	129.6	<200
L3 [V]	264.5	265.3	265.4	265.5	264.5±2.3
Trip time [ms]	100	131.2	99.2	133.2	<200
L1L2L3 [V]	264.5	265.8	265.7	265.4	264.5±2.3
Trip time [ms]	100	131.6	130.8	112.4	<200




D.3	Overvoltage 10 min mean Protection		P	
	Output Voltage (V)	Switch		
		On/Off state		Finally
100% Un	230.24	<input checked="" type="checkbox"/> On	<input type="checkbox"/> Off	--
112% Un	257.55	<input type="checkbox"/> On	<input checked="" type="checkbox"/> Off	489.0
100% Un	230.24	<input checked="" type="checkbox"/> On	<input type="checkbox"/> Off	--
108% Un	248.55	<input checked="" type="checkbox"/> On	<input type="checkbox"/> Off	--
106% Un	243.97	<input checked="" type="checkbox"/> On	<input type="checkbox"/> Off	--
114% Un	261.84	<input type="checkbox"/> On	<input checked="" type="checkbox"/> Off	289.5





Un to 1.12Un



Un to 1.08Un






D.3 Table: Islanding									P
No.	$P_{EUT}^{1)}$ (%of EUT rating)	Reactive load (% of Q_L in 6.1.d) ¹⁾	$P_{AC}^{2)}$ (% of nominal)	$Q_{AC}^{3)}$ (% of nominal)	Run on time (ms)	P_{EUT} (W)	Actual Q_f	V_{DC}	Remarks ⁴⁾
1	100	100	0	0	254.0	60000	1.00	785	Test A at BL
2	66	66	0	0	559.0	39600	1.00	690	Test B at BL
3	33	33	0	0	532.0	19800	1.00	576	Test C at BL
4	100	100	-5	-5	181.0	60000	0.98	785	Test A at IB
5	100	100	-5	0	201.0	60000	1.00	785	Test A at IB
6	100	100	-5	5	210.0	60000	1.02	785	Test A at IB
7	100	100	0	-5	243.0	60000	0.98	785	Test A at IB
8	100	100	0	5	230.0	60000	1.00	785	Test A at IB
9	100	100	5	-5	202.0	60000	0.96	785	Test A at IB
10	100	100	5	0	192.0	60000	0.97	785	Test A at IB
11	100	100	5	5	171.0	60000	1.00	785	Test A at IB
12	66	66	0	-5	207.6	39600	0.97	690	Test B at IB
13	66	66	0	-4	212.8	39600	0.98	690	Test B at IB
14	66	66	0	-3	220.4	39600	0.98	690	Test B at IB
15	66	66	0	-2	246.0	39600	0.99	690	Test B at IB
16	66	66	0	-1	331.0	39600	0.99	690	Test B at IB
17	66	66	0	1	371.0	39600	0.99	690	Test B at IB
18	66	66	0	2	297.6	39600	1.00	690	Test B at IB
19	66	66	0	3	227.6	39600	0.99	690	Test B at IB
20	66	66	0	4	213.6	39600	1.02	690	Test B at IB
21	66	66	0	5	199.2	39600	1.01	690	Test B at IB
22	33	33	0	-5	205.6	19800	0.96	576	Test C at IB
23	33	33	0	-4	207.2	19800	0.97	576	Test C at IB
24	33	33	0	-3	226.0	19800	0.98	576	Test C at IB
25	33	33	0	-2	290.4	19800	0.99	576	Test C at IB
26	33	33	0	-1	359.0	19800	0.98	576	Test C at IB
27	33	33	0	1	308.0	19800	0.99	576	Test C at IB
28	33	33	0	2	242.4	19800	0.99	576	Test C at IB
29	33	33	0	3	216.0	19800	1.00	576	Test C at IB
30	33	33	0	4	206.0	19800	1.01	576	Test C at IB
31	33	33	0	5	190.8	19800	1.02	576	Test C at IB

Remark:

- 1) P_{EUT} : EUT output power
- 2) P_{AC} : Real power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0% test condition value.
- 3) Q_{AC} : Reactive power flow at S1 in Figure 1. Positive means power from EUT to utility. Nominal is the 0% test condition value.
- 4) BL: Balance condition, IB: Imbalance condition.
- 5) *Note: test condition A (100%): If any of the recorded run-on times are longer than the one recorded for the rated balance condition, i.e. test procedure 6.1 f), then the non-shaded parameter combinations (no.32~47) also require testing.





4.4.4		TABLE: Single fault tolerance				P
No.	Component name	Component No.	Fault point	Duration	Result	
1.	ISO Relay	K1	Short circuit before start up inverter	3min	Unit can't operating, error message: Iso Fault. No danger ,no hazard ,no fires	
2.	Monitoring Relay - L1	RL3	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
3.	Monitoring Relay - L1	RL3	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
4.	Monitoring Relay - L1	RL9	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
5.	Monitoring Relay - L1	RL9	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
6.	Monitoring Relay - L2	RL2	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
7.	Monitoring Relay - L2	RL2	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
8.	Monitoring Relay - L2	RL8	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
9.	Monitoring Relay - L2	RL8	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
10.	Monitoring Relay - L3	RL1	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
11.	Monitoring Relay - L3	RL1	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
12.	Monitoring Relay - L3	RL7	Pin1 to Pin2 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
13.	Monitoring Relay - L3	RL7	Pin3 to Pin4 short circuit before start up inverter	3min	Unit can't operating, error message: Grid Relay Fault. No danger ,no hazard ,no fires	
14.	AC voltage measure1	R777	Pin1-Pin2 Short circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires	
15.	AC voltage measure1	R783	Pin1-Pin2 Open circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires	
16.	AC voltage measure2	R784	Pin1-Pin2 Short circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires	
17.	AC voltage measure2	R790	Pin1-Pin2 Open circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires	

18.	AC voltage measure3	R791	Pin1-Pin2 Short circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires
19.	AC voltage measure3	R797	Pin1-Pin2 Open circuit	3min	Unit shut down, Error message: Grid Volt Fault. no danger ,no hazard ,no fires
20.	AC current measure1	R571	Pin1-Pin2 Short circuit	3min	Unit can't operating, error message: Inv Over Current. No damage ,no hazard ,no fire.
21.	AC current measure2	R581	Pin1-Pin2 Short circuit	3min	Unit can't operating, error message: Inv Over Current. No damage ,no hazard ,no fire.
22.	AC current measure3	R593	Pin1-Pin2 Short circuit	3min	Unit can't operating, error message: Inv Over Current. No damage ,no hazard ,no fire.
23.	AC frequency measure	R555	Pin1-Pin2 Open circuit	3min	Unit shut down, error message: Grid Freq Fault. No damage ,no hazard ,no fire
24.	V-bus measure	R492	Pin1-Pin2 Short circuit	3min	Unit shut down ,error massage: BusAllVoltHwOveFault. No damage ,no hazard ,no fire
25.	V-bus measure	R100	Pin1-Pin2 Short circuit	3min	Unit can't start up No damage ,no hazard ,no fire
26.	DC current measure	U26	Pin1-Pin2 Short circuit	3min	Unit shut down,error message: PV1HwoVerCurrFault. no danger ,no hazard ,no fires
27.	Bus cap	C41	Pin1-Pin2 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
28.	COM-of CPU1-CPU2	C258	Pin 172 Open circuit	3min	Unit shut down. error message: Slave Com Waring. No damage, no hazard, no fire.
29.	CPU1 Failure -Power	R159	Pin 1-Pin2 Short circuit	3min	Unit shut down. No damage ,no hazard ,no fire
30.	T measure	U7	Pin1-Pin2 Short circuit	3min	Unit can't operating,Error massage: CoolingTemAdChanWarning. No damage, no hazard, no fire.
31.	Insulation impedance measure	Q2	Pin1-Pin2 Short circuit	3min	Unit can't operating,Error massage: Iso Err. No damage, no hazard, no fire.
32.	Drive optocoupler	Q2	Pin1-Pin2 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
33.	power tube Boost	Q2	Pin1-Pin2 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
34.	power tube Boost	D20	Pin1-Pin3 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
35.	power tube Boost	TQ6	Pin2-Pin3 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
36.	Diode	U26	Short circuit	3min	Unit normal operation, No danger ,no hazard ,no fires
37.	power tube IGBT - inverter	C41	Pin1-Pin2 Short circuit before start up	3min	Unit can't start ,error message: Hardware Fault, No damage ,no hazard ,no fire

38.	power tube IGBT - inverter	TQ6	Pin1-Pin3 Short circuit before start up	3min	Unit can't start ,error message: Hardware Fault, No damage ,no hazard ,no fire
39.	GFCI check	R553	Short circuit	3min	Unit shut down, error message: GFCI Fault. No damage ,no hazard ,no fire
40.	Power supply +20V	T1	Pin10-Pin11 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
41.	Power supply +8V	T1	Pin25-Pin26 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
42.	Power supply +12V	T1	Pin27-Pin29 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
43.	Power supply +12V	T1	Pin132-Pin34 Short circuit before start up	3min	Unit can not start up, No damage, no hazard, no fire.
44.	power tube MOS-SPS	Q3	G-D Short circuit	3min	SPS no output, no danger ,no hazard ,no fires
45.	Output L1 to N	--	short circuit	3min	Unit shut down ,error message: Grid Volt Fault. No damage ,no hazard ,no fire
46.	Output L1 to L2	--	short circuit	3min	Unit shut down ,error message: Grid Volt Fault. No damage ,no hazard ,no fire
47.	Output L to PE	--	short circuit	3min	Unit shut down ,error message: Grid Volt Fault. No damage ,no hazard ,no fire
48.	Output N to PE	--	short circuit	3min	Unit shut down ,error message: Grid Volt Fault. No damage ,no hazard ,no fire
49.	Overload	--	Output overload (110%)	30 min	Unit normal operation, No damage ,no hazard ,no fire
50.	Cooling system failure – Blanketing test	--	Put the unit to box	2Hour	1 hour power run at 80%
51.	PV+ to PV-	--	Reverse polarity	3min	Unit can not start up, no danger ,no hazard ,no fires
52.	Output L - N	--	Reverse polarity before start up	3min	Unit normal operation. No damage, no hazard, no fire.
53.	Output L1 - N	--	Reverse polarity before start up	3min	Unit can't operating, error message: Grid Volt Fault. No damage ,no hazard ,no fire
54.	Output L1 - L2	--	Reverse polarity before start up	3min	Unit normal operation. No damage, no hazard, no fire.

Remarks:


Abbreviations APS:auxiliary power supply, EM: error message
, EUT: equipment under test, SC short circuit, OP: open circuit, O/L: Overloaded
EUT shut down: EUT not connect to Grid ,cease to export power to Grid, the relay is opened.
EUT standby: EUT connect to Grid ,cease to export power to Grid, the relay is closed.

During the test:

Fire can not propagates beyond the EUT;
Equipment shall not emitt molten metal;
Enclosures shall not deform to cause non-compliance with the standard.
Dielectric test is made on RI and BI between Pri. circuit and protective earthing terminal after the test.
No Backfeed voltage on the test


D.4.1		Table: Operating frequency range				P
		Frequency domain		Duration		
		47,5 Hz – 49,0 Hz		30 minutes		
		49,0 Hz – 51,0 Hz		Permanent		
		51,0 Hz – 51,5 Hz		30 minutes		
Steps	f (Hz)	f (Hz) Measured	Time	Time measured	Comments	
1	47.5 Hz	47.50	>30 min	35min	Operated normally.	
2	49.0 Hz	49.00	Permanent	100min	Operated normally.	
3	51.0 Hz	51.00	Permanent	100min	Operated normally.	
4	51.5 Hz	51.50	>30 min	35min	Operated normally.	
5	52.5 Hz	52.50	>15 min	20min	Operated normally.	

D.4.2 **Table: Minimal requirements for active power delivery at underfrequency** **P**




Step	f (Hz)	fmea. (Hz)	T (s)	T meas. (s)	P (%) - max	P (%) - min	P meas. (%)
1	50.00 ± 0.05	50.00	>60	103	100%	100%	100.09%
2	49.50 ± 0.05	49.50	>60	120	100%	100%	100.09%
3	49.00 ± 0.05	49.00	>60	120	100%	100%	100.09%
4	48.50 ± 0.05	48.50	>60	120	100%	99%	100.09%
5	48.00 ± 0.05	48.00	>60	120	100%	98%	100.10%
6	47.50 ± 0.05	47.50	>60	120	100%	97%	100.09%

Supplementary information:




D.4.3 Table: Continuous voltage operation range					P
Step	Voltage (%)	P (%)	P meas. (%)	Time (s)	T meas (s)
1	100	100	100.07%	>60	70
2	85	100 (*)	93.70%	>120	130
3	100	100	100.08%	>5	30
4	110	100	100.08%	>120	130

(*) Active power reduction is allowed due to current limitation.





D.5.1	Table: Rate of change of frequency (ROCOF)					P
Steps	Overfrequency			Underfrequency		
	f (Hz)	Step time (s)	Output power (W)	f (Hz)	Step time (s)	Output power (W)
1	50.0 to 51.0	0.5	59966	50.0 to 49.0	0.5	60211
2	51.0 to 51.5	0.5	60259	49.0 to 47.5	1.5	60197
3	51.5	1	60143	47.5	1	59970
4	51.5 to 51.0	0.5 s	60124	47.5 to 49.0	1.5	60075
5	51.0	3.0 s	60115	49.0	0.5	60157

Overfrequency




Underfrequency






Test at full load (>90%)						
Udip	Type	t min (ms)	U meas. (%)	T meas.(ms)	P recover (s)	
5%	1 ph	Phase A	5.27/99.96/100.00	260	0.076	
		Phase B	99.48/5.15/100.00	264	0.087	
		Phase C	100.00/99.04/5.17	262	0.092	
	2 ph	Phase A & B	5.23/4.82/100.00	261	0.071	
		Phase B & C	100.00/5.18/4.82	262	0.070	
		Phase C & A	5.32/100.00/5.12	265	0.087	
	3 ph	5.00/5.34/5.00	269	0.084		
25%	1 ph	Phase A	100.57/25.13/100.00	1002	0.078	
		Phase B	25.25/99.26/100.00	1001	0.072	
		Phase C	100.00/100.09/24.90	998	0.075	
	2 ph	Phase A & B	24.77/25.07/100.00	1010	0.089	
		Phase B & C	100.00/25.12/24.62	1013	0.085	
		Phase C & A	24.96/100.00/24.82	999	0.076	
	3 ph	25.26/24.71/5.00	1004	0.089		
50%	1 ph	Phase A	99.96/50.17/100.00	1851	0.086	
		Phase B	50.52/98.96/100.00	1851	0.084	
		Phase C	100.00/99.13/49.52	1852	0.087	
	2 ph	Phase A & B	50.39/49.87/100.00	1851	0.086	
		Phase B & C	100.00/50.35/49.74	1846	0.086	
		Phase C & A	50.22/100.00/49.52	1856	0.082	
	3 ph	50.78/49.87/50.00	1846	0.087		
75%	1 ph	Phase A	100.78/74.26/100.00	2706	0.063	
		Phase B	75.78/99.39/100.00	2701	0.096	
		Phase C	100.00/101.13/75.79	2697	0.084	
	2 ph	Phase A & B	75.30/76.00/100.00	2716	0.083	
		Phase B & C	100.00/76.17/75.61	2705	0.091	
		Phase C & A	74.61/100.00/75.87	2709	0.095	
	3 ph	75.35/75.83/75.00	2701	0.095		



Remark:
The tests are performed together with clause 4.7.4.2.2 Zero current mode and enabling of default setting:
Undervoltage of 70%Un.



Graph_5%






Graph_25%




D.5.2		Table: UVRT				P	
Test at partial load (30%Pn)							
Udip	Type	t min (ms)	U meas. (%)	T meas.(ms)	P recover (s)		
5%	1 ph	Phase A	100.87/4.75/100.00	264	0.070		
		Phase B	4.79/100.17/100.00	279	0.091		
		Phase C	100.00/99.65/5.02	272	0.081		
	2 ph	Phase A & B	250	5.24/5.26/100.00	271	0.079	
		Phase B & C	100.00/5.31/4.88	268	0.082		
		Phase C & A	5.12/100.00/5.36	272	0.081		
	3 ph	5.36/5.21/5.00	274	0.096			
25%	1 ph	Phase A	100.09/24.75/100.00	1004	0.073		
		Phase B	24.77/100.26/100.00	1000	0.077		
		Phase C	100.00/100.17/24.70	1005	0.072		
	2 ph	Phase A & B	938	24.71/24.97/100.00	1000	0.077	
		Phase B & C	100.00/24.98/24.69	1003	0.072		
		Phase C & A	25.07/100.00/25.03	1002	0.075		
	3 ph	25.37/25.38/25.00	1005	0.074			
50%	1 ph	Phase A	100.70/49.61/100.00	1843	0.093		
		Phase B	50.70/99.61/100.00	1852	0.083		
		Phase C	100.83/50.83/100.00	1853	0.087		
	2 ph	Phase A & B	1797	49.48/50.09/100.00	1851	0.083	
		Phase B & C	100.00/49.91/49.96	1847	0.084		
		Phase C & A	50.78/100.00/49.13	1853	0.083		
	3 ph	50.78/50.09/50.00	1849	0.084			
75%	1 ph	Phase A	99.22/75.83/100.00	2702	0.094		
		Phase B	75.70/99.09/100.00	2695	0.076		
		Phase C	100.00/100.30/74.22	2704	0.074		
	2 ph	Phase A & B	2656	75.35/75.91/100.00	2706	0.090	
		Phase B & C	100.00/74.83/76.22	2704	0.092		
		Phase C & A	75.04/100.00/76.00	2688	0.088		
	3 ph	75.96/76.35/75.00	2702	0.075			

Remark:
The tests are performed together with clause 4.7.4.2.2 Zero current mode and enabling of default setting: undervoltage of 70%Un.






Graph_50%





Graph_75%


D.6.1	Table: Power response to over frequency						P
Grid tied mode							
Test 1	100% P _n , f ₁ =50.2Hz; droop=12%; f-stop deactivated, with delay of 2 s						
	f (Hz)	Measured output Power (W)	Calculated from standard characteristic curve P (W)	Tolerance between measured P and calculated P (W)	Tolerance Limit (W)	For a reduction of active power of 50% P _{max} T≤2s	For a reduction of active power T≤20s
50Hz ± 0.01Hz	50.00	60035.32	60000	--	--	--	--
50.2Hz ± 0.01Hz	50.20	59925.85	60000	--	--	--	--
50.70Hz ± 0.01Hz	50.70	55341.27	55000	341.27	± 6000	0.4s	0.8s
51.15Hz ± 0.01Hz	51.15	51175.90	50500	675.90	± 6000	0.4s	0.6s
52.0Hz ± 0.01Hz	52.00	42800.48	42000	800.48	± 6000	0.4s	0.8s
51.15Hz ± 0.01Hz	51.15	51130.15	50500	630.15	± 6000	0.2s	0.4s
50.70Hz ± 0.01Hz	50.70	55241.98	55000	241.98	± 6000	0.2s	0.4s
50.2Hz ± 0.01Hz	50.20	59958.92	60000	-41.08	± 6000	0.4s	0.6s
50Hz ± 0.01Hz	50.00	60017.04	60000	--	--	--	--
Test 2	100% P _n , f ₁ =50.2Hz; droop=2%; f-stop deactivated, no delay						
	f (Hz)	Measured output Power (W)	Calculated from standard characteristic curve P (W)	Tolerance between measured P and calculated P (W)	Tolerance Limit (W)	For a reduction of active power of 50% P _{max} T≤2s	For a reduction of active power T≤20s
50Hz ± 0.01Hz	50.00	60063.43	--	--	--	--	--
50.2Hz ± 0.01Hz	50.20	59939.68	--	--	--	--	--
50.70Hz ± 0.01Hz	50.70	30692.77	30000	692.77	± 6000	0.4s	0.6s
51.15Hz ± 0.01Hz	51.15	4709.79	3000	1709.79	± 6000	0.4s	0.8s
52.0Hz ± 0.01Hz	52.00	223.28	0	223.28	± 6000	0.4s	0.6s
51.15Hz ± 0.01Hz	51.15	4456.75	3000	1456.75	± 6000	0.6s	0.8s
50.70Hz ± 0.01Hz	50.70	30252.40	30000	252.40	± 6000	0.4s	0.4s
50.2Hz ± 0.01Hz	50.20	59777.62	--	--	--	0.4s	0.6s
50Hz ± 0.01Hz	50.00	60029.74	--	--	--	--	--

Test 3	50% P _n , f ₁ =52.0Hz; droop=5%; f-stop deactivated, no delay						
	f (Hz)	Measured output Power (W)	Calculated from standard characteristic curve P (W)	Tolerance between measured P and calculated P (W)	Tolerance Limit (W)	For a reduction of active power of 50% P _{max} T≤2s	For a reduction of active power T≤20s
50Hz ± 0.01Hz	50.00	30326.33	--	--	--	--	--
51.0Hz ± 0.01Hz	51.00	30420.18	30000.00	420.18	± 6000	--	--
51.70Hz ± 0.01Hz	51.70	30451.13	30000.00	451.13	± 6000	--	--
52.0Hz ± 0.01Hz	52.00	30451.52	30000.00	451.52	± 6000	--	--
51.70Hz ± 0.01Hz	51.70	30476.67	30000.00	476.67	± 6000	--	--
51.00Hz ± 0.01Hz	51.00	30485.38	30000.00	485.38	± 6000	--	--
50Hz ± 0.01Hz	50.00	30365.14	--	--	--	--	--
Test 4	100% P _n , f ₁ =50.2Hz; droop=5%; f-stop =50.1, no delay, Deactivation time t _{stop} 30s						
	f (Hz)	Measured output Power (W)	Calculated from standard characteristic curve P (W)	Tolerance between measured P and calculated P (W)	Tolerance Limit (W)	For a reduction of active power of 50% P _{max} T≤2s	For a reduction of active power T≤20s
50Hz ± 0.01Hz	50.00	59969.24	60000	--	--	--	--
50.2Hz ± 0.01Hz	50.20	59800.58	60000	--	--	--	--
50.70Hz ± 0.01Hz	50.70	47055.03	48000	-944.97	± 6000	0.4s	0.6s
51.15Hz ± 0.01Hz	51.15	36650.15	37200	-549.85	± 6000	0.2s	0.4s
52.0Hz ± 0.01Hz	52.00	17070.00	16800	270.00	± 6000	0.4s	0.6s
51.15Hz ± 0.01Hz	51.15	16962.45	16800	162.45	± 6000	--	--
50.70Hz ± 0.01Hz	50.70	16958.87	16800	158.87	± 6000	--	--
50.2Hz ± 0.01Hz	50.20	16949.80	16800	--	--	--	--
50Hz ± 0.01Hz	50.00	60057.88	60000	--	--	--	--









D.7.1	Table: Q Capabilities (Power Factor)	P
--------------	---	----------




Figure 12 — Reactive power capability at nominal voltage

Leading PF=0.9:

P/Pn[%] setpoint	P[W]	Q[Var]	Cosφ	Cosφ setpoint	Δcosφ	Q[Var] setpoint	ΔQ/S _{max} [%]	LIMITE [%]
10	6178.82	3498.70	0.8697	0.9	-0.0434	2905.93	0.10	± 2
20	12263.42	5967.68	0.8992	0.9	0.0000	5811.87	0.05	± 2
30	18329.55	8918.56	0.8992	0.9	-0.0005	8717.80	0.10	± 2
40	24370.35	11832.58	0.8996	0.9	-0.0014	11623.73	0.14	± 2
50	30381.24	14775.86	0.8993	0.9	-0.0002	14529.66	0.21	± 2
60	36356.64	17648.90	0.8996	0.9	-0.0004	17435.60	0.21	± 2
70	42326.99	20531.96	0.8997	0.9	-0.0004	20341.53	0.22	± 2
80	48298.74	23437.19	0.8997	0.9	-0.0006	23247.46	0.25	± 2
90	54258.43	26356.55	0.8995	0.9	-0.0008	26153.39	0.30	± 2
100*	54429.89	26306.34	0.9004	0.9	0.0015	--	--	--

* Remark: Due to the max current limit, the active power can't get to 100%.


Lagging PF=-0.9:

P/Pn[%] setpoint	P[W]	Q[Var]	Cosφ	Cosφ setpoint	Δcosφ	Q[Var] setpoint	ΔQ/S _{max} [%]	LIMITE [%]
10	6249.76	-3143.37	0.8931	0.9	-0.0437	-2905.93	-0.04	± 2
20	12391.62	-6035.21	0.8990	0.9	-0.0011	-5811.87	-0.07	± 2
30	18585.03	-9031.70	0.8994	0.9	0.0029	-8717.80	-0.16	± 2
40	24761.87	-12009.62	0.8998	0.9	0.0017	-11623.73	-0.26	± 2
50	30894.44	-14941.95	0.9002	0.9	0.0020	-14529.66	-0.34	± 2
60	37049.66	-17957.15	0.8999	0.9	0.0017	-17435.60	-0.52	± 2
70	42230.55	-20395.59	0.9005	0.9	0.0013	-20341.53	-0.06	± 2
80	48227.72	-23351.84	0.9001	0.9	0.0012	-23247.46	-0.14	± 2
90	54220.76	-26205.25	0.9004	0.9	0.0010	-26153.39	-0.08	± 2
100*	54407.73	-26227.27	0.9008	0.9	0.0013	--	--	--

* Remark: Due to the max current limit, the active power can't get to 100%.

Q=0:

D.7.1 Table: Q Capabilities (Power Factor)								P
P/Pn[%] setpoint	P[W]	Q[Var]	Cosφ	Cosφ Set-point	Δcosφ	Q[Var] setpoint	ΔQ/S _{max} [%]	LIMITE [%]
10	6353.05	391.82	0.9980	1.0	-0.0061	0.00	0.07	± 2
20	12668.69	1109.56	0.9962	1.0	-0.0011	0.00	0.37	± 2
30	19011.69	1260.33	0.9978	1.0	-0.0005	0.00	0.63	± 2
40	24085.73	1367.08	0.9984	1.0	-0.0004	0.00	0.91	± 2
50	30133.86	1533.97	0.9987	1.0	-0.0003	0.00	1.28	± 2
60	36145.32	1739.59	0.9988	1.0	-0.0002	0.00	1.74	± 2
70	42375.97	1513.50	0.9994	1.0	-0.0001	0.00	1.77	± 2
80	48264.05	708.43	0.9999	1.0	-0.0001	0.00	0.94	± 2
90	54479.76	738.15	0.9999	1.0	-0.0001	0.00	1.11	± 2
100	60293.54	904.02	0.9999	1.0	-0.0001	0.00	1.51	± 2




Graph

D.7.1 Table: Q Capabilities (Power Factor)						P
Q=43.58%P_D						
P/Pn[%] setpoint	P[W]	Q[Var]	Cosφ	Q[Var] setpoint	ΔQ/S _{max} [%]	LIMITE [%]
10	5689.93	25798.22	0.22	26148.00	-0.58	± 2
20	11778.10	25718.93	0.42	26148.00	-0.72	± 2
30	17857.51	25819.79	0.57	26148.00	-0.55	± 2
40	23911.83	25711.11	0.68	26148.00	-0.73	± 2
50	29952.58	25824.22	0.76	26148.00	-0.54	± 2
60	35972.69	25726.75	0.81	26148.00	-0.70	± 2
70	42003.19	25849.13	0.85	26148.00	-0.50	± 2
80	47996.61	25951.36	0.88	26148.00	-0.33	± 2
90	54090.77	25913.66	0.90	26148.00	-0.39	± 2
100*	53446.79	26045.88	0.90	26148.00	-0.17	± 2
Q=-43.58%P_D						
P/Pn[%] setpoint	P[W]	Q[Var]	Cosφ	Q[Var] setpoint	ΔQ/S _{max} [%]	LIMITE [%]
10	6634.49	-26207.66	0.25	-26148.00	-0.10	± 2
20	12726.72	-26083.34	0.44	-26148.00	0.11	± 2
30	18793.79	-25936.72	0.59	-26148.00	0.35	± 2
40	24864.78	-25818.44	0.69	-26148.00	0.55	± 2
50	31065.74	-25820.57	0.77	-26148.00	0.55	± 2
60	37116.20	-25670.94	0.82	-26148.00	0.80	± 2
70	42960.65	-26030.07	0.86	-26148.00	0.20	± 2
80	48948.86	-25911.83	0.88	-26148.00	0.39	± 2
90	54887.58	-26151.11	0.90	-26148.00	-0.01	± 2
100*	53536.14	-26033.75	0.90	-26148.00	0.19	± 2

* Remark: Due to the max current limit, the active power can't get to 100%.

Graph



D.7.1 Table: Q(U) Capabilities P





Figure 13 — Reactive power capability at active power P_D in the voltage range (positive sequence component of the fundamental)

Over-excited:						
AC output				Reactive power measured		
Voltage setting [V/V _n]	Measured			Reactive power [Var]	Value [Q/P _D]	Limits
	Voltage [V]	[V/V _n]	Active power [W]			
1.10	252.79	1.10	60858.60	790.48	0.0130	±0.02
1.08	248.33	1.08	60865.41	11506.02	0.1890	0.194±0.02
1.05	241.53	1.05	59231.70	28726.06	0.4850	0.484±0.02
1.00	230.10	1.00	59163.80	28656.55	0.4844	0.484±0.02
0.95	218.40	0.95	56528.01	27300.99	0.4830	--
0.92	211.38	0.92	54320.92	26315.06	0.4844	--
0.90	207.01	0.90	53297.69	25803.14	0.4841	--
0.85	195.49	0.85	50512.87	24424.90	0.4835	--


Under-excited:						
AC output				Reactive power measured		
Voltage setting [V/V _n]	Measured			Reactive power [Var]	Value [Q/P _D]	Limits
	Voltage [V]	[V/V _n]	Active power [W]			
1.10	252.49	1.10	59486.55	-28815.69	-0.4844	-0.484±0.02
1.08	247.89	1.08	59487.94	-28793.05	-0.4840	-0.484±0.02
1.05	240.89	1.05	59065.14	-28637.26	-0.4848	-0.484±0.02
1.00	229.91	1.00	59260.63	-28408.52	-0.4794	-0.484±0.02
0.95	217.99	0.95	55736.73	-26429.59	-0.4742	--
0.92	211.24	0.92	59266.46	-11437.08	-0.1930	-0.194±0.02
0.90	206.63	0.90	59240.87	-819.21	-0.0138	±0.02

D.7.1 Table: Q Control. Voltage related control mode						P
P/Pn [%] Setpoint	Vac [V] Setpoint	P/Pn [%] measured	Vac [V] Measured	Q [VAr] measured	Q [Var] expected	ΔQ [Var] ($\leq \pm 5 \%Pn$)
< 20 %	1.07 Vn	18.11	246.03	777.96	≈ 0 (< $\pm 5 \% Pn$)	1.30
< 20 %	1.09 Vn	18.13	250.59	861.36	≈ 0 (< $\pm 5 \% Pn$)	1.44
<20 % to 30 %	1.09 Vn	30.15	250.54	-13075.21	-13074.00 (Within 10sec)	0.00
40 %	1.09 Vn	40.44	250.58	-13123.17	-13074.00	-0.08
50 %	1.09 Vn	50.68	250.61	-13095.04	-13074.00	-0.04
60 %	1.09 Vn	60.63	250.57	-13145.26	-13074.00	-0.12
70 %	1.09 Vn	70.34	250.61	-13053.40	-13074.00	0.03
80 %	1.09 Vn	80.54	250.57	-13050.78	-13074.00	0.04
90 %	1.09 Vn	90.53	250.54	-13080.81	-13074.00	-0.01
100 %	1.09 Vn	100.00	250.58	-13041.11	-13074.00	0.05
100 %	1.1 Vn	99.23	252.80	-27388.80	-26148.00	-2.07
100 % to 10 %	1.1 Vn	9.72	252.69	-26225.83	-26148.00	-0.13
10 % to $\leq 5 \%$	1.1 Vn	4.52	252.88	845.92	≈ 0 (< $\pm 5 \% Pn$)	1.41
P/Pn [%] Set-point	Vac [V] Set- point	P/Pn [%] measured	Vac [V] Measured	Q [VAr] measured	Q [Var] expected	ΔQ [Var] ($\leq \pm 5 \%Pn$)
< 20 %	0.93 Vn	18.11	213.77	440.07	≈ 0 (< $\pm 5 \% Pn$)	0.73
< 20 %	0.91 Vn	18.10	209.18	394.84	≈ 0 (< $\pm 5 \% Pn$)	0.66
<20 % to 30 %	0.91 Vn	29.77	209.14	13230.93	13074.00 (Within 10sec)	0.26
40 %	0.91 Vn	39.86	209.21	13212.92	13074.00	0.23
50 %	0.91 Vn	49.97	209.16	13132.22	13074.00	0.10
60 %	0.91 Vn	60.20	209.23	13123.89	13074.00	0.08
70 %	0.91 Vn	70.23	209.19	13157.47	13074.00	0.14
80 %	0.91 Vn	80.67	209.15	13187.11	13074.00	0.19
90 %	0.91 Vn	90.28	209.20	13148.32	13074.00	0.12
100 %	0.91 Vn	96.84	209.24	13435.32	13074.00	0.60
100 %	0.90 Vn	89.05	206.94	25322.93	26148.80	-1.38
100 % to 10 %	0.90 Vn	9.50	206.65	25195.07	26148.80	-1.59
10 % to $\leq 5 \%$	0.91 Vn	4.31	209.15	364.77	≈ 0 (< $\pm 5 \% Pn$)	0.61

D.7.1 Table: Q Control. Voltage related control mode P



Graph: Lock-in at 1.08Vn




Graph: Lock-in at 0.92Vn

D.7.1 Table: Q Control Power related control modes								P
P Desired (%Sn)	P measured (%Sn)	Q measured (Var)	Voltage Desired (%Un)	Voltage Measured (%Un)	Power Factor desired (cos φ)	Power Factor measured (cos φ)	ΔQ (%S _{Max})	Limit (%S _{Max})
20%	20.25	685.54	<105%	103.49	1.0000	0.9984	1.04	±2
30%	30.28	639.10	<105%	103.54	1.0000	0.9994	0.97	±2
40%	40.33	850.55	<105%	103.60	1.0000	0.9994	1.29	±2
50%	50.36	749.19	<105%	103.66	1.0000	0.9997	1.14	±2
60%	60.34	1090.72	<105%	103.78	1.0000	0.9995	1.65	±2
60%	60.32	6972.61	>105%	106.09	0.9800	0.9817	0.51	±2
70%	70.21	12330.02	>105%	106.17	0.9600	0.9597	-0.12	±2
80%	80.16	17451.23	>105%	106.25	0.9400	0.9400	-0.04	±2
90%	89.98	23053.69	>105%	106.34	0.9200	0.9197	-0.08	±2
100%	97.10	28199.36	>105%	106.25	0.9000	0.9001	1.30	±2
100%	100.06	1154.50	<100%	99.83	1.0000	0.9997	1.75	±2

Remark: Tested at lock-in voltage 1.05 Vn and lock-out voltage Vn.
The Lock-in value is adjustable between Vn and 1.1Vn in 0.01V steps, the Lock-out value is adjustable between 0.9Vn and Vn in 0.01V steps

Graph



D.7.2 Table: Voltage related active power reduction P(U) P






Figure 15 - Example curve for P(U)

Step#	Set voltage vaule V/Vn [%]	Measured voltage vaule V/Vn[%]	Measured power values[W]	Measured power bin[%]	Limit[%]	RESULT
1	100	100.00	60156	100.26	--	P
2	102	101.98	60203	100.34	--	
3	104	104.00	60233	100.39	--	
4	106	106.00	60256	100.43	--	
5	108	108.00	60266	100.44	--	
6	110	110.02	45501	75.84	<80	
7	112	112.00	25001	41.67	<60	




D.8		Table: Connection and reconnection			P
Parameter		Reconnection after tripping of the interface protection relay	Normal operation starting relay		
Lower frequency		49,9 Hz	49,9 Hz		
Upper frequency		50,1 Hz	50,1 Hz		
Lower voltage		If connection to the LV distribution network: 85% U_n	If connection to the LV distribution network: 85% U_n		
		If connection to the HV distribution network: 90 % U_e	If connection to the HV distribution network: 90 % U_e		
Upper voltage		If connection to the LV distribution network: 110 % U_n	If connection to the LV distribution network: 110 % U_n		
		If connection to the HV distribution network: 110 % U_e	If connection to the HV distribution network: 110 % U_e		
Observation time		60 s	60 s		
Maximum active power increase gradient		10 %/min*	20 %/min		
* Power-generating units that have not the ability to apply a certain gradient shall take into account an additional delay.					
Test sequence after trip	connection	connection allowed	Observation time (s)	Power gradient after connection (%/min)	
Step a)	<49.9Hz	No	--	--	
Step b)	≥49.9Hz	Yes	60.0	9.79	
Step c)	>50.1Hz	No	--	--	
Step d)	≤50.1Hz	Yes	63.0	9.62	
Step e)	<195.5V	No	--	--	
Step f)	≥195.5V	Yes	64.5	9.56	
Step g)	>253V	No	--	--	
Step h)	≤253V	Yes	65.0	9.33	
Remark: Maximum active power increase gradient 10 %/min.					


D.8	Table: Connection and reconnection	P
------------	---	----------




Graph_49.9Hz



Graph_50.1Hz





Graph_195.5V




Graph_253V


D.8 Starting to generate electrical power				P				
Test sequence at normal operation starting	connection	connection allowed	Observation time (s)	Power gradient after connection (%/min)				
Step a)	<49.9Hz	No	--	--				
Step b)	≥49.9Hz	Yes	61.0	9.62				
Step c)	>50.1Hz	No	--	--				
Step d)	≤50.1Hz	Yes	62.0	9.55				
Step e)	<195.5V	No	--	--				
Step f)	≥195.5V	Yes	60.0	9.74				
Step g)	>253V	No	-- </tr <tr> <td>Step h)</td> <td>≤253V</td> <td>Yes</td> <td>71.5</td> <td>9.73</td> </tr>	Step h)	≤253V	Yes	71.5	9.73
Step h)	≤253V	Yes	71.5	9.73				



D.8	Starting to generate electrical power	P
------------	--	----------





Graph_195.5V



Graph_253V

D.9 Table: Ceasing and reduction of active power on set point (Logic interface)							P
String	4	U _{DC} =	620 Vdc	U _{ac} = U _n	230 Vac	P _{Emax} (KW)	60
1 min mean value P/P _n		P _{measured} (%)		ΔP _{measured} (%)		Limit [%]	
Psetpoint (%)							
100%		100.71%		0.71%		±5%	
90%		91.38%		1.38%		±5%	
80%		81.36%		1.36%		±5%	
70%		71.23%		1.23%		±5%	
60%		61.18%		1.18%		±5%	
50%		50.84%		0.84%		±5%	
40%		40.76%		0.76%		±5%	
30%		30.84%		0.84%		±5%	
20%		20.92%		0.92%		±5%	
10%		10.79%		0.79%		±5%	
The power gradient for increasing and reducing (%P _n /s)							0.48%P _n /s
Time for Logic interface (at input port) activated							2.024s




Annex 1: Photo document

Front




Back



Annex 1: Photo document

Left




Right



Annex 1: Photo document

Top



Bottom



Annex 1: Photo document

Internal

